


SECOND FLOOR PLAN

- LEGEND:**
- (#) = SAMPLE NUMBER/LOCATION
  - (+) = POSITIVE ACM RESULT
  - (F) = FIRE DOORS
  - [Red] = RM218, FLOOR MASTIC, NON-FRIABLE, 3.3% CHRYSOTILE (350SF), FLOOR TILE NEGATIVE
  - [Yellow] = RM216, FLOOR TILE, NON-FRIABLE, 0.39% CHRYSOTILE, MASTIC 5.4% CHRYSOTILE (680SF)
  - [Orange] = RM204, TAN FLOOR TILE, NON-FRIABLE, 7.2% CHRYSOTILE, MASTIC 8.0% CHRYSOTILE (100SF)
  - [Light Blue] = RM238, TAN/GREY FLOOR TILE, NON-FRIABLE, 5.7% CHRYSOTILE, MASTIC 7.0% CHRYSOTILE (96SF)
  - [Medium Blue] = RM232, GREY FLOOR TILE, NON-FRIABLE, 7.6% CHRYSOTILE, MASTIC 10.0% CHRYSOTILE (700SF)
  - [Dark Blue] = RM233, TAN FLOOR TILE, NON-FRIABLE, 5.0% CHRYSOTILE (580SF), MASTIC NEGATIVE
  - [Purple] = RM237, 9"x9" TAN FLOOR TILE, NON-FRIABLE, 4.1% CHRYSOTILE, MASTIC 10.0% CHRYSOTILE (20SF)
  - [Light Green] = RM247, TAN/GREY FLOOR TILE, NON-FRIABLE, 5.3% CHRYSOTILE, MASTIC 10.0% CHRYSOTILE (400SF)
  - [Dark Green] = RM246, TAN/GREY FLOOR TILE, NON-FRIABLE, 8.2% CHRYSOTILE, MASTIC 10.0% CHRYSOTILE (1500SF)
  - [Light Green] = FLOOR MASTIC, NON-FRIABLE, 6-10% CHRYSOTILE (20000SF), FLOOR TILE NEGATIVE
  - [Purple] = RM245, TAN/GREY FLOOR TILE, NON-FRIABLE, 5.9% CHRYSOTILE, MASTIC 1.7% CHRYSOTILE (275SF)



**MONTGOMERY COLLEGE  
TECHNICAL CENTER**  
ROCKVILLE, MARYLAND

CONTENT:

REVISED:	DATE	COMMENT

DATE: 19 MAR 03

SCALE: NTS

**ENV-2**